

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 470

Date: 06-07-2026

It is certified that an inspection team headed by KASHISH BANSAL (Junior Engineer)
(Name of Officers
with designation) from Water Supply + Sanitation Subdiv. Malout (Name of
Department/Office) inspected the Oracle International School
Mt. Jandwala Charat Singh Malout (Name & Address of
the School) on 02-07-2026 and found that the Oracle International
School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 31-03-2027

Signature with Seal :

Sub Divisional Engineer
W/S & Sanitation Sub Division

Name :

ANIL KUMAR

Designation :

Sub divisional Engineer
Subdiv. Malout

To

Principal
Oracle International School
Jandwala Charat Singh Malout
(Name & Address of the Institution)

BLOCK WATER TESTING LABORATORY, MALOUT

Water Supply & Sanitation Sub Division 3, BSNL Exchange Road, Malout
blwtmalout@gmail.com

TEST REPORT

Name & Address of Customer : Principal, Oracle International School Oracle International School, Jandwala Charat Singh		Customer Reference No.	No : OIS/2026-27/138 Dated : 03/06/2026
		Sample Submitted by	Rajjot Kaur
		Date of Sample Receipt	04/06/2026
		Analysis Starting Date	05/06/2026
		Analysis completion Date	08/06/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC000126000000124F	Sample Type :	Treated Water
Test Report No.:	BWTL/MLT/2627/00106	Date of Issue :	08/06/2026
Registration no.:	BWTL/MLT/REG2627/00231	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Oracle International School, Jandwala Charat Singh / NA
Village :	Jandwala Charat Singh	Habitation :	Jandwala Charat Singh
Block:	Malout	District :	Muktsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.36	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	90	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	T. Alkalinity(CaCO ₃)	26	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	T. Hardness(CaCO ₃)	42	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
8	Calcium(Ca)	10	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
9	Magnesium(Mg)	4	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride(Cl)	18	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Malout

End of the Test Report

BLOCK WATER TESTING LABORATORY, MALOUT

Water Supply & Sanitation Sub Division 3, BSNL Exchange Road, Malout
blwtlmalout@gmail.com

To,

Principal, Oracle International School
Oracle International School, Jandwala Charat Singh

No.: BWTL/MLT/2627/00106 Dated : 08/06/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. OIS/2026-27/138 Dated: 03/06/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 04/06/2026. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Malout

D/A : Test Report



**Authorized Signatory
For, Block Water Testing Laboratory
Malout**